



Attestation of Conformity

No. N8A 088072 0058 Rev. 00

Holder of Attestation: AOK Industrial Company Limited

1/F of 1#Building
East Block of 3/F of Building 1
And 2/F of Building 4, ST George's Science and Technology
Industrial Park
Northside of Xinyu Road
Xiangshan Community
Xinqiao Street Baoan District
518000 Shenzhen, Guangdong
PEOPLE'S REPUBLIC OF CHINA

**Product: Flood lights
(LED Flood Light)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 68140260244101

Date, 2026-05-12

(Taylor Yao)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 088072 0058 Rev. 00

Model(s):

AOK-ZWFLC(M)-NV-A5-BB-XXYY-BN-P;
 AOK-ZWFLC(L)-NV-A5-BB-XXYY-BN-P;
 AOK-ZWFLC(XL)-NV-A5-BB-XXYY-BN-P;
 AOK-ZWFLC(M)-NV-L5-BB-XXYY-BN-P;
 AOK-ZWFLC(L)-NV-L5-BB-XXYY-BN-P;
 AOK-ZWFLC(XL)-NV-L5-BB-XXYY-BN-P;
 AOK-ZWFLC(M)-NV-L3-BB-XXYY-BN-P;
 AOK-ZWFLC(L)-NV-L3-BB-XXYY-BN-P ;
 ('Z' stands for Rated Power, can be 20-500, in steps
 of 1W, e.g. 20=20W, 500=500W;
 'BB' stands for whether with Zhaga socket &
 sealing cap, can be 00 and SN, 00= without Zhaga
 socket & sealing cap, SN= with Zhaga socket &
 sealing cap;
 'XX' stands for CCT of LED, can be 27, 30, 40, 50, 57
 and 65, 27=2700K, 30=3000K, 40=4000K, 50=5000K,
 57=5700K, 65=6500K;
 'YY' stands for CRI (color rendering index), can be
 70 and 80, 70=Ra: 70, 80=Ra: 80;
 'P' stands for internal code, can be A, B, C)

Brand:

AOK



Parameters:

Rated Voltage: 120-277VAC
 Rated Frequency: 50/60Hz
 Rated Power: See below table for details
 Protection Class: I
 Degree of Protection: IP66
 Blue Light Hazard Group: BLH-B
 ta: 50°C

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Attestation of Conformity

No. N8A 088072 0058 Rev. 00

Model No.	'Z' can be 20 to 500 which stands for Rated Power 20W to 500W, in steps of 1W	Rated Power (W)
AOK-ZWFLC(M)-NV-A5-BB-XXYY-BN-P	Z=20 to 240	20-240
AOK-ZWFLC(L)-NV-A5-BB-XXYY-BN-P	Z=101 to 500	101-500
AOK-ZWFLC(XL)-NV-A5-BB-XXYY-BN-P	Z=241 to 500	241-500
AOK-ZWFLC(M)-NV-L5-BB-XXYY-BN-P	Z=20 to 240	20-240
AOK-ZWFLC(L)-NV-L5-BB-XXYY-BN-P	Z=101 to 500	101-500
AOK-ZWFLC(XL)-NV-L5-BB-XXYY-BN-P	Z=241 to 500	241-500
AOK-ZWFLC(M)-NV-L3-BB-XXYY-BN-P	Z=20 to 240	20-240
AOK-ZWFLC(L)-NV-L3-BB-XXYY-BN-P	Z=101 to 240	101-240

**Tested
according to:**

EN 60598-2-5:2015
EN IEC 60598-1:2024/A11:2024
EN 62493:2015/A1:2022

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.