




TEST REPORT

| | |
|--|--|
| Kunde: <i>Client:</i> | AOK Industrial Company Limited |
| Adresse: <i>Address:</i> | 1/F of 1#Building, East Block of 3/F of Building 1, And 2/F of Building 4, ST George's Science and Technology Industrial Park, Northside of Xinyu Road, Xiangshan Community, Xianqiao Street Baoan District, 518000 Shenzhen, Guangdong, CHINA |
| Hersteller: <i>Manufacturer:</i> | AOK Industrial Company Limited |
| Adresse: <i>Address:</i> | 1/F of 1#Building, East Block of 3/F of Building 1, And 2/F of Building 4, ST George's Science and Technology Industrial Park, Northside of Xinyu Road, Xiangshan Community, Xianqiao Street Baoan District, 518000 Shenzhen, Guangdong, CHINA |
| Name der Marke: <i>Brand Name:</i> |  |
| Beschreibung des Produkts: <i>Product Description:</i> | LED STADIUM LIGHT |
| Modelle: <i>Models:</i> | See model list on page 2 |
| Bewertung: <i>Rating:</i> | See model list on page 2 |
| Verfahren: <i>Method:</i> | Clause 9 of IEC 60598-1:2020 |
| Prüfergebnis*: <i>Test result*:</i> | Pass |

Datum der Prüfung:
Date of Test:

2022/12/29

Datum der Emission:
Date of Issue:

2023/1/5

Klassifizierung:
Classification:

Commission Test

Gegenstand der Prüfung:
Test item:

IP66 Test

Prüflabor (Testlabor) / Testing Laboratory:
Shenzhen Southern LCS Compliance Testing Laboratory Ltd.

Test von/Test by:

Rebecca Qin

Rebecca Qin/ Project Engineer

Check von/Check by:

Torres He

Torres He/ Director

Genehmigt von/Approved by:

Jesse Liu

Jesse Liu/ Manager

Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.

Remark: The duplication of this report or parts of it and its use for advertising purposes is only allowed with permission of the testing laboratory. This report contains the result of examination of the product sample submitted by the appliance. A general statement concerning the quality of the products from the series manufacturer cannot be derived therefore.



Shenzhen Southern LCS Compliance Testing Laboratory Ltd.

Add: 101-201, No.39 Building, Xialang Industrial Zone, Heshuikou Community, Matian Street, Guangming District, Shenzhen, China

Tel: +(86) 0755-29871520 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com

Scan code to check authenticity

**General remarks:**

1. The test results presented in this report relate only to the object tested.
2. This report shall not be reproduced, except in full, without the written approval of the Issuing Testing Laboratory. The authenticity of this Test Report and its contents can be verified by contacting the Testing Laboratory, responsible for this Test Report.
3. The general information of applicant and manufacturer (such as the name and address), product name, model/type reference, trademark and other similar information contained in this report are all provided by the applicant, the laboratory is not responsible for verifying its authenticity.

Modified Information

| Version | Report No. | Revision Date | Summary |
|---------|----------------|---------------|------------------|
| V1.0 | LCSB111822018S | / | Original Version |

General product information:

- All models have the same structure and appearance except power and LED bead are difference .
- Unless otherwise specified, the model AOK-1200WiSF-HV-00-S5-5070-30-U was chosen as representative model to perform all test.

Model list:

| Model | Rating | LED driver |
|----------------------------------|--------------------------|----------------|
| AOK-400WiSF-NV-00-aa-bbcc-zz-y-e | 100-277V~, 50/60Hz, 400W | EUD-480S280DV |
| | | EUD-480S280SV |
| AOK-400WiSF-HV-00-aa-bbcc-zz-y-e | 277-480V~, 50/60Hz, 400W | ESD-480S-280DV |
| | | ESD-480S280DV |
| | | ESD-480S280SV |
| AOK-600WiSF-NV-00-aa-bbcc-zz-y-e | 100-277V~, 50/60Hz, 600W | EUM-680S560MG |
| | | EUM-680S560LG |
| | | EUM- 680S560BG |
| | | EUM- 680S560DG |
| | | EUM-680S560SG |
| AOK-600WiSF-HV-00-aa-bbcc-zz-y-e | 277-480V~, 50/60Hz, 600W | ESM-680S560MG |
| | | ESM-680S560LG |
| | | ESM-680S560BG |
| | | ESM- 680S560DG |
| | | ESM-680S560SG |
| AOK-800WiSF-NV-00-aa-bbcc-zz-y-e | 100-277V~, 50/60Hz, 800W | EUM-880S700MG |
| | | EUM-880S700LG |
| | | EUM- 880S700BG |
| | | EUM- 880S700DG |
| | | EUM-880S700SG |





| | | |
|---|---------------------------|----------------------|
| AOK-800WiSF-HV-00-aa-bbcc-zz-y-e | 277-480V~, 50/60Hz, 800W | ESM-880S700MG |
| | | ESM-880S700LG |
| | | ESM-880S700BG |
| | | ESM- 880S700DG |
| | | ESM-880S700SG |
| AOK- 1200WiSF-NV-00-aa-bbcc-zz-y-e | 100-277V~, 50/60Hz, 1200W | EUM-680S560MG (2pcs) |
| | | EBM- 1K2S740DG |
| | | EBM- 1K2S740MG |
| | | EBM-1K2S740SG |
| AOK- 1200WiSF-HV-00-aa-bbcc-zz-y-e | 100-277V~, 50/60Hz, 1200W | EUM-680S560MG (2pcs) |
| | 277-480V~, 50/60Hz, 1200W | ESM- 1K2S740MG |
| | | ESM-1K2S740LG |
| | | ESM- 1K2S740BG |
| | | ESM- 1K2S740DG |
| ESM-1K2S740SG | | |
| AOK- 1500WiSF-HV-dd-aa-bbcc-zz-y-e | 200-480V~, 50/60Hz, 1500W | MT1800H200CQ780 |
| | | MT1800H200CQI 780 |
| AOK- 1800WiSF-HV-dd-aa-bbcc-zz-y-e | 200-410V~, 50/60Hz, 1800W | MT1800H200CQ780 |
| | | MT1800H200CQI 780 |
| Remark: "dd"=00 or DV represent electrical function, 00=Normal, DV=DALI. "aa"=S5 or S35 represent LED type, S5=Seoul 5050, S35=Seoul 3535. "bb"=27~ 65 any integer" represent the CCT, e.g. 27=2700K, 57=5700K. "cc" Represent CRI, can be 70, 80 or 90. "zz"=15, 20, 30, 35 or PG60" represent view angle of LED lens, 15=15°, 20=2030, 30=30°, 35=3585, PG60=125*60°. "y"= A, C or U represent different mounting brackets, A=type A top fixed, C=type C top fixed, U=Yoke Mount. "e"= A or Blank represent product type, A=split type, Blank=All-in-one | | |

Equipment used during test:

| ID Number | Instrument | Model/ Type | Calibration Date |
|------------|---------------------------------|-------------|------------------|
| SLCS-S-031 | Sand and dust test box | SG-500 | 2022/5/10 |
| SLCS-S-034 | IPX5, IPX6 waterproof equipment | JL-1/2 | 2022/5/10 |
| SLCS-S-135 | Digital hygrometer thermometer | HTC-1 | 2022/5/10 |
| SLCS-S-072 | Torque Driver | 26RTD | 2022/5/10 |
| SLCS-S-073 | Hi-pot tester | AN9602M | 2022/5/10 |



Shenzhen Southern LCS Compliance Testing Laboratory Ltd.
Add: 101-201, No.39 Building, Xialang Industrial Zone, Heshuikou Community, Matian Street, Guangming District, Shenzhen, China
Tel: +(86) 0755-29871520 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity



| | | | |
|------------|----------------------|-----------|-----------|
| SLCS-S-062 | Frequency Converter | AN97020TS | 2022/5/10 |
| SLCS-S-059 | Digital Power Meter | PF9800 | 2022/5/10 |
| SLCS-S-011 | J Thermocouple | J | 2022/5/10 |
| SLCS-S-029 | Temperature recorder | 34970A | 2022/5/10 |



**Test Item:**

Tests for protection against dust-proof: IP6X

Test Method:

The tests should be carried out under the standard atmospheric condition.

Temperature range: 20°C to 30°C.

Dust-proof luminaires (first characteristic IP numeral 6) shall be tested in a dust chamber similar to that shown in Figure 2, in which talcum powder is maintained in suspension by an air current.

The chamber shall contain 2 kg of powder for every cubic metre of its volume. The talcum powder used shall be able to pass through a square-meshed sieve whose nominal wire diameter is 50 µm and whose nominal free distance between wires is 75 µm. It shall not have been used for more than 20 tests.

The test shall proceed as follows.

- The luminaire is suspended outside the dust chamber and operated at rated supply voltage until operating temperature is achieved.
- The luminaire, whilst still operating, is placed with the minimum disturbance in the dust chamber.
- The door of the dust chamber is closed.
- The fan/blower causing the talcum powder to be in suspension is switched on.

After 1 min, the luminaire is switched off and allowed to cool for 3 h whilst the talcum powder remains in suspension.

NOTE: The 1 min interval between switching on the fan/blower and switching off the luminaire is to ensure that the talcum powder is properly in suspension around the luminaire during initial cooling, which is most important with smaller luminaires. The luminaire is operated initially as in item a) to ensure the test chamber is not overheated.

Acceptance Conditions:


After completion of the tests, the luminaire shall withstand the electric strength test specified in Section 10, and inspection shall show:

No deposit of talcum powder inside enclosures for dust-tight luminaires.

Test Result:

☒ Pass ☐ Fail





IEC 280/01

NOTE See IEC 60068-2-68, figure 2 valid for La2 only.

Figure 2 – Test device to verify protection against dust (dust chamber)



**Test Item:**

Tests for protection against ingress moisture: IPX6

Test Method:

The tests should be carried out under the standard atmospheric condition.

Temperature range: 20°C to 30°C.

Jet-proof luminaires (second characteristic IP numeral 6) are switched off and immediately subjected to a water jet for 3 min from all directions by means of a hose having a nozzle with the shape and dimensions shown in Figure 8. The nozzle shall be held 3 m away the sample.

The water pressure at the nozzle shall be adjusted to achieve a water flow rate of 12,5 l/min \pm 5 % (approximately 30 100 kN/m²).

Before the tests for the second characteristic numeral, with the exception of IPX8, the luminaire complete with lamp(s) shall be switched on and brought to a stable operating temperature at rated voltage.

The water for the tests shall be at a temperature of 15 °C \pm 10 °C.

Luminaires shall be mounted and wired as in normal use and placed in the most unfavourable position, complete with their protective translucent covers, if any, for the tests of IP.

Where connection is made by a plug or a similar device, then this shall be regarded as part of the complete luminaire and shall be included in the tests and similarly for any separate controlgear.

For tests of IP, fixed luminaire intended for mounting with its body in contact with a surface shall be tested with an expanded metal spacer interposed between the luminaire and the mounting surface.

The spacer shall be at least equal in overall size to the projection of the luminaire, and have dimensions as follows:

| | |
|-------------------|------------------|
| Longway of mesh | 10 mm to 20 mm |
| Shortway of mesh | 4 mm to 7 mm |
| Strand width | 1,5 mm to 2 mm |
| Strand thickness | 0,3 mm to 0,5 mm |
| Overall thickness | 1,8 mm to 3 mm |

Luminaires having provision for draining water by means of drain holes shall be mounted with the lowest drain hole open unless otherwise specified in the manufacturer's installation instructions.

If the installation instructions indicate that a luminaire is for ceiling or under-canopy mounting, the luminaire shall be attached to the underside of a flat board or plate which extends 10 mm beyond that part of the luminaire perimeter in contact with the mounting surface.

For recessed luminaires, the parts in the recess and the parts protruding from the recess shall each be tested according to their IP classification as indicated in the manufacturer's mounting instructions. A box encapsulating the part in the recess may be necessary for the test of IP.

Note: Portable luminaires, wired as in normal use, shall be placed in the most unfavourable position of normal use.

Glands, if any, shall be tightened with a torque equal to two-thirds of that applied to glands in the test of 4.12.5.

Fixing screws of covers, other than hand-operated fixing screws of glass covers, shall be tightened with a torque equal to two-thirds of that specified in Table 4.1.

Screwed lids shall be tightened with a torque having a value in newton metres numerically equal to one-tenth of



Shenzhen Southern LCS Compliance Testing Laboratory Ltd.

Add: 101-201, No.39 Building, Xialang Industrial Zone, Heshuikou Community, Matian Street, Guangming District, Shenzhen, China

Tel: +(86) 0755-29871520 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com

Scan code to check authenticity



the nominal diameter of the screw thread in millimetres. Screws fixing other caps shall be tightened with a torque equal to two-thirds of that specified in Table 4.1.

Acceptance Conditions:

After completion of the tests, the luminaire shall withstand the electric strength test specified in Section 10, and inspection shall show:


No trace of water on electrical connections, current carrying parts or on insulation where it could become a hazard for the user or surroundings, for example where it could reduce the creepage distances below the values specified in Section 11; the only exception to this is for SELV conductors where the voltage under load does not exceed 12 V r.m.s. or 30 V ripple free d.c. and the conductors are protected from corrosion.

For luminaires without drain holes, there shall be no water entry.

For luminaires with drain holes, water entry including condensation is allowed during the tests if it can drain out effectively and provided it does not reduce the creepage and clearance distances below the minimum levels specified in the standard.

Test Result:

☒ Pass ☐ Fail



$D' = 6,3$ mm for the test of 9.2.6 (second characteristic numeral 5)

$D' = 12,5$ mm for the test of 9.2.7 (second characteristic numeral 6)




Shenzhen Southern LCS Compliance Testing Laboratory Ltd.

Add: 101-201, No.39 Building, Xialang Industrial Zone, Heshuikou Community, Matian Street, Guangming District, Shenzhen, China

Tel: +(86) 0755-29871520 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com

Scan code to check authenticity



IEC 492/08

Dimensions in millimetres

Figure 8 – Nozzle for spray test

Table 4.1 – Torque tests on screws

| Nominal outer thread diameter of screw mm | Torque Nm | | |
|--|--------------|--------|-------|
| | 1 | 2 | 3 |
| Up to and including 2,8 | 0,20 | 0,40 | 0,40 |
| Over 2,8 up to and including 3,0 | 0,25 | 0,50 | 0,50 |
| Over 3,0 up to and including 3,2 | 0,30 | 0,60 | 0,50 |
| Over 3,2 up to and including 3,6 | 0,40 | 0,80 | 0,60 |
| Over 3,6 up to and including 4,1 | 0,70 | 1,20 | 0,60 |
| Over 4,1 up to and including 4,7 | 0,80 | 1,80 | 0,90 |
| Over 4,7 up to and including 5,3 | 0,80 | 2,00 | 1,00 |
| Over 5,3 up to and including 6,0 | – | 2,50 | 1,25 |
| Over 6,0 up to and including 8,0 | – | 8,00 | 4,00 |
| Over 8,0 up to and including 10,0 | – | 17,00 | 8,50 |
| Over 10,0 up to and including 12,0 | – | 29,00 | 14,50 |
| Over 12,0 up to and including 14,0 | – | 48,00 | 24,00 |
| Over 14,0 up to and including 16,0 | – | 114,00 | 57,00 |





Table 4.2 – Torque tests on glands

| Diameter of test rod mm | Moment | |
|----------------------------|--------------------|------------------------------|
| | Metal glands Nm | Moulded plastic glands Nm |
| Up to 7 | 6,25 | 2,5 |
| Over 7 up to 14 | 6,25 | 3,25 |
| Over 14 up to 20 | 7,50 | 5 |
| Over 20 | 10 | 7,50 |

Withstand the electric strength after IP6X test:

| Test Location | Test Voltage | Broken or Flashover |
|---------------------------------|--------------|---|
| Live parts and accessible parts | 1554V | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |

Withstand the electric strength after IPX6 test:

| | | |
|---------------------------------|-------|---|
| Live parts and accessible parts | 1554V | <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
|---------------------------------|-------|---|





Photo Documentation:

Photo 1: Overall view of model AOK-1200WiSF-HV-00-S5-5070-30-U



Photo 2: Overall view of model AOK-1200WiSF-HV-00-S5-5070-30-U






Photo Documentation:

Photo 3: IP6X test of model AOK-1200WiSF-HV-00-S5-5070-30-U



Photo 4: IPX6 test of model AOK-1200WiSF-HV-00-S5-5070-30-U



**Photo Documentation:**

Photo 5: Test result after IP6X and IPX6 test




Photo 6: Test result after IP6X and IPX6 test

**----- End of Test Report -----**

Shenzhen Southern LCS Compliance Testing Laboratory Ltd.
Add: 101-201, No.39 Building, Xialang Industrial Zone, Heshuikou Community, Matian Street, Guangming District, Shenzhen, China
Tel: +(86) 0755-29871520 | E-mail: webmaster@lcs-cert.com | Web: www.lcs-cert.com
Scan code to check authenticity